

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-24-03-12-01

- Products:** SPC FLOORINGS
Construction: UV lacquered wear layer, colour film layer, SPC core, with and without pre-attached EVA backing layer (1,0-1,5) mm or (1,0-1,5) mm IXPE backing layer
Total dimensions: length (450-3200) mm x width (90-1600) mm x thickness (3,2-7,5) mm
- Producer:** ASIA US INDUSTRIAL JOINT STOCK COMPANY
Lot 1, Thai Hoa, Lien Son, Lien Hoa IZ
Hoa Son Town
LAP THACH DISTRICT, VINH PHUC PROVINCE
VIETNAM
- Order:** Testing and classification of selected properties according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling)
- Test report:** 2708003/297, 2708003/269, 2708003/232
- Test results:** *The above mentioned SPC floorings can be classified regarding to the tested properties according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling) as follows:*

Properties	Results	Declaration according to EN 14041:2004+AC:2005+AC:2006
Reaction to fire performance according to EN ISO 9239-1:2010 and EN ISO 11925-2:2020, Classification according to EN 13501-1:2018 - Critical heat flux - Smoke production - Extent of flame \leq 150 mm	10,57 kW/m ² 600,0 % x min fulfilled	Reaction to fire class B _{fl} -s1*
Formaldehyde emission according to EN 717-1:2004:10	< LOD (96 h)	Class E1
Sliding behavior according to EN 13893:2002-11	$\mu = 0,30$	Class DS

* Valid on wooden or mineral subfloor in end use application, using adhesive or not. / LOD = Limit of Detection

Dresden, 03/04/2024



P.P. R. Pusch

Head of laboratory

[Signature]

Engineer in charge