

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

AMY Hoa Son Joint Stock Company

Thai Hoa - Lien Son- Lien Hoa IZ, Lien Hoa Commune, Phu Tho Province, Vinh Phuc, VietNam

For the following product(s):

Vinyl Tile:

- WPC/Hybrid flooring + EVA (Maximum thickness:14.2mm including underlayment EVA)
- WPC/Hybrid flooring + CORK (Maximum thickness:14.2mm including underlayment CORK)
- WPC/Hybrid flooring + IXPE (Maximum thickness: 14.2mm including underlayment IXPE)
- WPC/Hybrid flooring without underlayment (Maximum thickness: 12.2mm)
- LVT Flooring (Luxury Vinyl Tile) (Maximum thickness: 5mm)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 v4.2-2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-20295

Valid from: April 01, 2026 to March 31, 2027

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION BODY



A handwritten signature in black ink, appearing to read "Diana Kirsanova Phillips".

Diana Kirsanova Phillips, Chief Assurance Officer,
SCS Global Services